

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

CD396
WSW
1/2-1
0.638 mi.
3369 ft.

MANHOLE 53063
WEST 23RD ST/MERMAID AV
BROOKLYN, NY

NY Spills **S104651559**
N/A

Site 1 of 2 in cluster CD

Relative:
Higher

Actual:
2 ft.

SPILLS:

Name: MANHOLE 53063
Address: WEST 23RD ST/MERMAID AV
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 0000155 / 2002-01-17
Facility ID: 0000155
Facility Type: ER
DER Facility ID: 149359
Site ID: 177755
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2000-04-04
Investigator: JHOCONNE
Referred To: Not reported
Reported to Dept: 2000-04-04
CID: 207
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2000-04-04
Spill Record Last Update: 2002-01-23
Spiller Name: CALLER
Spiller Company: CON ED
Spiller Address: 4 IRVING PL
Spiller Company: 001
Contact Name: MIKE CESARE
DEC Memo: "Prior to Sept, 2004 data translation this spill Lead_DEC Field was O'CONNELL Con Ed e2mis #130745 Notes: 4-4-00 1730hrs 1 pint dielectric fluid coming from paper cable on 150gal water in manhole 53063. No other oil filled equipment in hole. Took sample. 4-5-00 1120hrs LSN 00-03279 <1ppm PCB 4-5-00 1510hrs Cleanup completed. Double washed with slix. Liquids removed by tanker, solids by vactor.

Remarks:

No leaking equipment. 10-2-01 1000hrs Checked structure and found no leaking cable."
"DEFECTIVE CABLE - CLEANUP PENDING SAMPLE RESULTS 1 QT SPILLED CON ED # 130745"

All Materials:

Site ID: 177755
Operable Unit ID: 821867
Operable Unit: 01
Material ID: 288419
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

Quantity: 1.00
Units: G
Recovered: .00
Oxygenate: Not reported